

NOTICE TO THE PUBLIC

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Aqua Pennsylvania Lake Latonka (PWSID# PA6430059)

BOIL WATER NOTICE LIFTED

ESTE INFORME CONTIENE INFORMACIÓN MUY IMPORTANTE SOBRE SU AGUA POTABLE.

TRADÚZCALO O HABLE CON ALGUIEN QUE LO ENTIENDA BIEN

The Boil Water Notice issued on Sunday, May 12, 2019 has been lifted effective today, Tuesday, May 14, 2019, for the Lake Latonka Water System.

What happened? What is being done? When will the problem be corrected?

Due to a failure of the disinfection system, chlorine disinfection dropped below the state- required minimum level. The disinfection system issue was corrected. Two sets of samples were collected from the distribution system on Sunday, May 12 and Monday, May 13 and tested for total coliform bacteria. Results from both sets of samples were absent of total coliform bacteria on Tuesday, May 14, 2019.

It is no longer necessary to use boiled water or bottled water for drinking, making ice, brushing teeth, washing dishes and food preparation.

Aqua is committed to providing quality water and service to its customers. We apologize for the inconvenience and thank you for your patience. Although this matter has been resolved, if you have any questions or concerns, please contact Aqua's Customer Service at 877.987.2782.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information, please contact:

Responsible Person Zachary Martin , Plant Manager II	System Name Lake Latonka	Address (Street) 644 N. Water Street
Phone Number 724.347.7418 x 0	System PWSID# PA6430059	Address (City, State, Zip) Sharon, PA 16146

Date Notice Distributed: May 14, 2019

Date Notice Lifted: May 14, 2019